

8 Cootamundra Cres.
Blackburn VIC 3130
AUSTRALIA
+61 (0)430 412 380
joshua@anzcompliance.com.au



Certificate No.: R22768

RCM CERTIFICATE

This certificate is issued to confirm that ANZ Electrical Compliance has certified the equipment described herein have comply with AS/NZS 4417.1 and can be marked with the Regulatory Compliance Mark.

Certificate Holder: TELTONIKA NETWORKS UAB
Barsausko g. 66
LT-51436 Kaunas
LITHUANIA

Product: Uninterruptable Power Supply

Trade Name / Manufacturer: TELTONIKA Networks

Model(s): BAT120

Ratings: Input: 9-30 Vd.c.,
Output: 9-30 Vd.c., 1.8 A
Class III

Compliance Details: See below.

EESS: Not in-scope (< 120Vd.c.)
Registered as Level 1 Equipment
Comply with AS/NZS 62368.1:2018
Test Report# SZES220700430301

ACMA/RSM: SDoC under Responsible Supplier E7663
Comply with AS/NZS CISPR 32:2015 +A1
Test Report Ref# SZEM220700534701

Issue Date: 9 January 2023



ANZ Electrical Compliance