

# BAT120 RCM

[Main Page](#) > [BAT Uninterruptable Power Supplies](#) > [BAT120](#) > [BAT120 Certification & Approvals](#) > **BAT120 RCM**



The **ACMA** regulatory arrangements require a supplier to apply a compliance label to a product before the product is supplied to the Australian market.



## Contents

- [1 Description](#)
- [2 Standards applied](#)
- [3 Attachments](#)
- [4 External links](#)

## Description



For all ACMA regulatory arrangements, the compliance label is the **Regulatory Compliance Mark (RCM)**. The RCM replaces the A-Tick and C-Tick compliance marks used under previous regulatory arrangements.

The RCM is a visible indication of a product's compliance with all applicable ACMA regulatory arrangements, including all technical and record-keeping requirements.

## Standards applied

The conformity with the essential requirements has been demonstrated against the following standards:

Standard	Description
AS/NZS CISPR 32: 2015+A1	Electromagnetic Compatibility of Multimedia Equipment - Emission requirements
AS/NZS 62368.1:2018	Information and Communication Technology Equipment - Safety requirements

## Attachments



RCM Certificate

You can find the PDF version of the RCM Certificate [here](#)

**Disclaimer:**

*Test reports that are referenced in declarations and certificates can be provided upon request. For the request to be approved, the recipient of the test reports should be a certification authority or certified test house. The recipients will be asked to sign a non-disclosure agreement (NDA).*

**External links**

- [Australian Communications and Media Authority](#)