

OPC UA Configuration Example

[Main Page](#) > [General Information](#) > [Configuration Examples](#) > [Router control and monitoring](#) > **OPC UA Configuration Example**

The information in this page is updated in accordance with [00.07.03.3](#) firmware version. .

□

Contents

- [1 Introduction](#)
- [2 Configuration overview and prerequisites](#)
- [3 Configuration](#)
 - [3.1 Defining Server and Nodes](#)
 - [3.2 Defining Value Groups and Values](#)
 - [3.3 Testing Data Retrieval](#)
 - [3.4 Sending Data to a Server](#)
- [4 See Also](#)

Introduction

OPC UA (OPC Unified Architecture) is an industrial communication protocol for secure and reliable transfer of real-time data and events between devices and applications in industrial automation and the Internet of Things (IoT).

This article will contain an example on how you can configure a Teltonika-Networks device as an OPC UA Client, that will gather and forward data from an OPC UA Server.

Note: OPC UA is additional software that can be installed from the **System → Package Manager** page.

Configuration overview and prerequisites

For this example we will need:

- **RUT or TRB series device** (RUTX11 will be used in this example)
- **OPC UA server**

Note: If you're having trouble finding any page or some of the parameters described here on your device's WebUI, you should turn on "**Advanced WebUI**" mode. You can do that by clicking the "**Basic**" button under "**Mode**", which is located at the top-right corner of the WebUI.

A visual GIF on how to change from Basic to Advanced:




✖

Configuration

Note: In this example, we will use a **OPC UA C++ demo server**, which has some predefined values simulated for us to request.





Required configurations are done inside **Services → OPC UA**

Defining Server and Nodes

1. In the **OPC UA Servers block**, insert the name of the server
2. Click **Add** to create new instance

3. Toggle **Enable** option to on
4. Insert the **URL** of the OPC UA Server
5. **Add** new server node

6. Enter the **ID Namespace** of the node
7. Select ID type as **String**
8. Enter **ID** of the node
9. **Save & Apply** settings

10. Optionally, add another node analogously



Defining Value Groups and Values

1. Insert the name of the **Value Group**
2. Press **Add** to add new value group

3. Enable the group and leave the rest of the settings as default

4. Inside the **OPC UA Group Values**, add new instance with your preferred name

5. **Enable** the instance
6. Assign a **server node** from which the data will be retrieved
7. **Save and apply** settings


Optionally configure the second value:



Testing Data Retrieval

Once we have our configuration finished, we can run some integrated tests in order to make sure we are able to retrieve the data from OPC UA server. In order to do so, we can press the **"Test"** button

under **OPC UA Value Groups**:



The output should show requested data like so:



Sending Data to a Server

Once we made sure we are able to read the values correctly using the test we did before, let us use "Data to server" to send this data to an HTTP server. For testing purposes, we will listen on defined port locally using Hercules software.

In order to do so navigate to **Services → Data to Server** and create a new data sender:

1. **Enable** the instance
2. Select Data source: **OPC UA**
3. Select Protocol: **HTTP(S)**
4. Adjust the JSON format to include the data
5. Define HTTP server IP



After saving these settings, we can start listening on "555" port using Hercules and see the data flow:



In conclusion, we have successfully configured an RUT device as an OPC UA client, requested data from an OPC UA demo server and forwarded that data using "Data to Server" functionality. By acting as an OPC UA client, RUT devices can seamlessly collect and transmit real-time data from various OPC UA servers to central monitoring systems.

Additionally, this integration demonstrates the flexibility and versatility of Teltonika-Networks devices in various industrial IoT applications and is a significant step forward in the development of a robust and scalable industrial IoT infrastructure.

See Also

- [OPC UA Manual](#)
- [OPC UA C++ Demo Server](#)
- [Hercules](#)